

DEPARTMENT OF TRANSPORTATION
 DIVISION OF ENGINEERING SERVICES
 STRUCTURE POLICY AND INNOVATION
 1727 30TH STREET
 P.O. BOX 168041
 SACRAMENTO, CA 95816-8041
 PHONE: (916) 227-8554



*Serious drought.
 Help save water!*

August 21, 2015

Mr. T.J. Bland
 Adhesives Technology Corp.
 450 East Copans Road
 Pompano Beach, FL 33064

Dear Mr. Bland:

This letter concerns the product "Ultrabond CA-DOT"

The California Department of Transportation (Caltrans) has completed the review of your company's product, "Ultrabond CA-DOT".

Based on the Department's review of the provided documents and fingerprint analysis, Ultrabond CA-DOT will be placed on the Authorized Materials List along with the requirements as shown below.

Manufacturer or Brand Name	Product Name	Threaded Rod			Reinforcing Bar (Gr. 60)	Concrete temp. at time of installation		Installation time at 25° C ^a	
		ASTM A 307	ASTM A 449 (T1)	F 593		Min (°C)	Max (°C)	Set (hrs)	Cure (hrs)
Adhesives Technology Corporation (800) 892-1880	Ultrabond CA-DOT	No	Yes	No	Yes	4	43	4.0	36.0

Foot notes ^a: The installation times are based on information in the Manufacturer's product literature. Set time is the minimum time needed for the adhesive to harden and support the anchor; cure time is the minimum time required before the anchor may be loaded.

If you have any questions, please feel free to call me at (916)227-8554.

Sincerely,

Craig Knapp
 Senior Bridge Engineer